



NOTES:

1. USE OF HYDRANT REQUIRES VALID WATER FIRE HYDRANT METER AGREEMENT. CONTACT WATER UTILITIES CUSTOMER SERVICE OFFICE FOR APPLICATION.
2. METER AND REDUCED BACKFLOW PRESSURE ZONE (RPZ) BACKFLOW ASSEMBLY SHALL BE FULLY SUPPORTED WHEN CONNECTED TO FIRE HYDRANT.
3. METER AND RPZ BACKFLOW ASSEMBLY SHALL BE APPROVED BY CITY OF ARLINGTON WATER UTILITIES. METER MUST BE OBTAINED FROM CITY OF ARLINGTON WATER UTILITIES. METER SHALL BE TESTED ANNUALLY BY CITY OF ARLINGTON WATER UTILITIES.
4. PRIOR TO ANY USE OF FIRE HYDRANT WATER, THE RPZ MUST BE TESTED BY A CITY-REGISTERED BACKFLOW PREVENTION ASSEMBLY TESTER (BPAT), AND A CURRENT AND PASSING TEST AND MAINTENANCE REPORT (TMR) FOR THE RPZ MUST BE FAXED TO WATER RESOURCE SERVICES AT (817)459-6626. BACKFLOW ASSEMBLY SHALL BE TESTED ANNUALLY AND EACH TIME THE ASSEMBLY IS MOVED TO A DIFFERENT FIRE HYDRANT SITE. COPY OF TEST SHALL BE SENT TO CITY OF ARLINGTON WATER UTILITIES WATER RESOURCE SERVICES BEFORE USAGE WILL BE ALLOWED.
5. CONTRACTOR WILL BE HELD RESPONSIBLE FOR ANY DAMAGE TO FIRE HYDRANT DURING USE.
6. SANDBAGS OR APPROVED SUPPORT SHALL NOT OBSTRUCT WEEP HOLE.

<span style="font-weight: bold; font-size: 0.8em;">CITY OF ARLINGTON, TEXAS</span>
<span style="font-weight: bold; font-size: 1.2em;">CONSTRUCTION WATER METER</span>
<small>DATE: 01/09/2018</small>